

Camignone di Passirano 08/07/2020

DECLARATION OF PERFORMANCE
No. DoP 00016

Unique identification code of the product-type

H1Z2Z2-K II Sect. 4 mm² diam. 5,60 mm

Intended use

Power, control and communication cables – Cables for general application in construction works subjected to reaction to fire requirements

Producer

Elettro Brescia S.p.A.
Via Bulloni 36
I – 25050 Camignone di Passirano (BS)

AVCP SYSTEM

1+

Classification report No

LSFIRE/E01282

Harmonized Standard

EN 50575:2014 + A1:2016

Notified Body

2479 – L.S. Fire Testing Institute S.r.l.

Notified product certification body no. 2479 performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance.

Agent

N.A.

Declared performance

Fire Reaction: B2ca-s1,d2,a1

Dangerous substances: none

This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Marco Del Corno
Quality and Laboratory Manager

