

CERTIFICATE OF COMPLIANCE

Certificate Number 20130912-S7256
Report Reference S7256-20121206
Issue Date 2013-SEPTEMBER-12

Issued to: PFANNENBERG GMBH
WERNER-WITT-STRASSE 1
POSTFACH 80 07 47
21007 HAMBURG GERMANY

This is to certify that representative samples of AUDIBLE-SIGNAL APPLIANCES, GENERAL SIGNAL;
VISUAL-SIGNAL APPLIANCES; AUDIBLE-SIGNAL APPLIANCES
See Addendum

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 464, Audible Signal Appliances
UL 1638, Visual Signaling Appliances - Private Mode
Emergency and General Utility Signaling
CSA C22.2 No. 205-M1983, Signaling Equipment -
Consumer and Commercial Products
CAN/ULC-S525-07, Audible Signal Devices for Fire Alarm
Systems, Including Accessories

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130912-S7256
Report Reference S7256-20121206
Issue Date 2013-SEPTEMBER-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

General Signaling Equipment:

Multi Tone Alarm Sounders Model: PA 1, PA 5, PA 10 and PA 20.

Models can be rated: 12-48Vdc, 24Vac, 115Vac (only for models PA 1 and PA 5), 230Vac (only for models PA 1 and PA 5) and 110-240Vac (only for model PA 10 and PA 20).

Multi Tone Alarm Sounders/Strobes Model: PA X 1-05, PA X 5-05, PA X-5-10, PA X 10-10, PA X 10-15, PA X 20-10, PA X 20-15.

Models can be rated: 12Vdc, 24Vdc, 24Vac, 48Vdc, 115Vac, 230Vac except for model PA X 5-10 which can be rated 115Vac, 230Vac

Fire Alarm Equipment:

Multi Tone Alarm Sounders Model: PA 1, PA 5, PA 10, PA 20.

Models can be rated: For Special Applications 24-48Vdc.

Model names may be followed by –SSM (only for models rated 24Vdc).



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

